

ASTA

CERTIFICATE OF TYPE TESTS

Laboratory Ref. No: LSWGWO0077036

Certificate No.....17899.....

APPARATUS: Range of 25A to 63A, 30mA,100mA, 300mA, Four Pole (FP) Residual Current operated Circuit Breakers without integral overcurrent protection for household and similar uses (RCCBs), 415V (U_n), 50/60Hz.

DESIGNATION: FTCT 25A-63A 4 pole 30,100, 300mA

MANUFACTURER: Farraj Trading & Manufacturing Co.,
P.O. Box 61122, Jebel Ali, Dubai, United Arab Emirates

TESTED BY: Electrical Research & Development Association
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, Gujarat, INDIA

DATES OF TESTS: 9th November 2009 to 13th August 2010

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with

IEC 61008-1: 2006
Test Sequences: A, B, C, D, E, F & G.

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above standard(s) and to justify the ratings assigned by the manufacturer as stated below.

For ratings assigned by the manufacturer and proved by the tests see page 1.

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 59 pages, 2 diagrams, 177 oscillograms, 64 photographs, 28 drawings and no other sheets as detailed on page 2 & 3

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission from ASTA BEAB Certification Services, Hilton House, Corporation Street, Rugby. CV21 2DN, England.



.....*Rajani Menon*.....
Rajani Menon
ASTA Observer
.....*P. Gibson*.....
Certification
Manager
.....5TH NOVEMBER 2010.....
Date

ASTA Certificates, ASTA Licences and ASTA Test Reports

ASTA Certificates, ASTA Licences and ASTA Test Reports are issued by Intertek for the exclusive use of the party applying for the Certificate, Licence or Test Report and any related testing. Intertek assumes no liability to any parties other than those with which it has an agreement and then only in accordance with the agreed Terms and Conditions.

The Applicant is authorised to copy or distribute ASTA Certificates, ASTA Licences and ASTA Test Reports provided the entire contents are included, or Certificate Front Sheets accompanied by any associated pages on which are stated the assigned rated characteristics and no part is obscured or illegible, or Licence front sheets. Permission must be obtained from Intertek before any other kind of reproduction is made.

The holder of an ASTA Certificate may claim in Trade Journals, Catalogues, Technical Articles etc., and without the prior approval of Intertek that the product identified in an ASTA Certificate is ASTA Certified.

The holder of an ASTA Licence may claim in Trade Journals, Catalogues, Technical Articles etc., and without the prior approval of Intertek that the product identified in an ASTA Licence is ASTA Approved.

To minimise the possibility of any misunderstanding such claims must clearly identify the product(s) certified or approved, the ratings verified by ASTA and the Standard against which certification/approval has been made.

Any other use of the Intertek or ASTA names must first be approved in writing by Intertek. Test results and ratings proven by testing included in ASTA Certificates and ASTA Test Reports relate specifically to the sample(s) tested.

Types of ASTA Certificates

Certificates are issued when samples of a particular product design have been tested satisfactorily against the requirements of a National, European, International or ASTA Standard. Several forms of Certificate are available, including:

Certificate of Complete Compliance

Verifies compliance with all the requirements of a Standard

Certificate of Type/Verification Tests

Verifies complete series of type/verification tests prescribed in a Standard has been made successfully.

Certificate of Selected Type/Verification Tests

Verifies specified type/verification tests have been made successfully

Supplementary Certificate

Extends the scope of an existing Certificate to cover changes in rating or in design

ASTA Test Report

An ASTA Test Report is issued when tests otherwise satisfactory cannot be included in a Certificate for one or more reasons, e.g. verification of non-standard ratings

ASTA Licences and ASTA Diamond Mark

The use of the ASTA Diamond Mark on products is authorised by an ASTA Licence. Products covered by an ASTA Licence can be referred to as ASTA Approved. Requirements for ASTA Licences include testing for full compliance with relevant standards and satisfactory, on-going assessment of production. Validity and use of ASTA Licences are subject to compliance with Intertek ASTA & BEAB Marks Certification Regulations.

Authenticity

Authenticity of any ASTA document can be confirmed by contacting Intertek's Rugby office, telephone +44 1788 578435 or asta@intertek.com

Ratings Assigned by the Manufacturer and Proved by Tests

Rated current (Range) (I_n):	25A, 32A, 40A & 63A
Rated residual operating current (Range) ($I_{\Delta n}$):	30mA, 100mA, 300mA
Rated residual non-operating current (Range) ($I_{\Delta no}$):	15mA, 50mA, 150mA
Rated voltage (U_n):	415V
Rated impulse withstand voltage (U_{imp}):	4kV
Number of Poles and current paths:	Four
Rated frequency:	50/60Hz
Rated making and breaking capacity (I_m):	10 I_n
Rated residual making and breaking capacity ($I_{\Delta m}$):	10 I_n
Rated conditional short-circuit current (I_{nc}):	10kA
Rated conditional residual short-circuit current ($I_{\Delta c}$):	3kA
Operating characteristics in case of residual current With d.c. components:	Type AC
Degree of protection:	IP20
Pollution degree/ Material Group:	2/II

1. **Test Sequence A:** Verified
(Clauses 6, 8.1.1, 8.1.2, 9.3, 8.1.3, 9.15, 9.4, 9.5, 9.6, 9.13, 8.1.3, 9.14)
2. **Test Sequence B:** Verified
(Clauses 9.7, 9.8, 9.20, 9.22.2, 9.23)
3. **Test Sequence C :** Verified
(Clauses 9.10)
4. **Test Sequence D (D_0 & D_1):** Verified
(Clauses 9.9, 9.17, 9.19, 9.21, 9.11.2.3, 9.16, 9.12, 9.18)
5. **Test Sequence E :** Verified
(Clauses 9.11.2.4 a), 9.11.2.2)
6. **Test Sequence F :** Verified
(Clauses 9.11.2.4 b), 9.11.2.4 c))
7. **Test Sequence G :** Verified
(Clauses 9.22.1)